



Stonington - Mystic System 2023 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	08/03/2023	None Detected
2	08/03/2023	None Detected
3	08/03/2023	None Detected
4	08/03/2023	None Detected
5	08/03/2023	None Detected
6	08/03/2023	None Detected
7	08/03/2023	None Detected
8	08/03/2023	None Detected
9	08/03/2023	None Detected
10	08/03/2023	None Detected
11	08/03/2023	None Detected
12	08/03/2023	None Detected
13	08/03/2023	None Detected
14	08/03/2023	None Detected
15	08/03/2023	None Detected
16	08/03/2023	None Detected
17	08/03/2023	None Detected
18	08/03/2023	None Detected
19	08/03/2023	None Detected
20	08/03/2023	None Detected
21	08/03/2023	None Detected
22	08/03/2023	None Detected
23	08/03/2023	None Detected
24	08/03/2023	None Detected
25	08/03/2023	None Detected
26	08/03/2023	None Detected



Rank	Collection Date	Lead Results (ppb)
27	08/03/2023	None Detected
28	08/03/2023	None Detected
29	08/03/2023	None Detected
30	08/03/2023	None Detected
31	08/03/2023	None Detected
32	08/03/2023	None Detected
33	08/03/2023	None Detected
34	08/03/2023	None Detected
35	08/03/2023	None Detected
36	08/03/2023	None Detected
37	08/03/2023	None Detected
38	08/03/2023	None Detected
39	08/03/2023	None Detected
40	08/03/2023	1
41	08/03/2023	2
42	08/03/2023	3

PWS ID#: CT1370011

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.