



AQUARION
Water Company

Stewards of the Environment™

Suffield System
2015 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	07/09/15	None Detected
2	07/09/15	None Detected
3	07/09/15	None Detected
4	07/09/15	None Detected
5	07/09/15	None Detected
6	07/09/15	None Detected
7	07/09/15	None Detected
8	07/09/15	None Detected
9	07/09/15	2
10	07/09/15	54

PWS ID#: CT1390021

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**