



## **Washington - Judea Depot System 2015 Lead Compliance Testing Results**

**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 3**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	09/02/2015	None Detected
2	08/18/2015	1
3	08/18/2015	1
4	08/25/2015	2
5	09/02/2015	2
6	08/25/2015	4

**PWS ID#: CT1500091**

**\*For additional information, please refer to the \*.pdf entitled: “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration.”**