



Washington - Judea Main System 2020 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 1

Rank	Collection Date	Lead Results (ppb)
1	03/27/20	None Detected
2	03/27/20	None Detected
3	03/27/20	None Detected
4	03/27/20	None Detected
5	03/27/20	None Detected
6	04/03/20	None Detected
7	03/27/20	1
8	03/27/20	1
9	03/27/20	1
10	04/03/20	1
11	03/27/20	3

PWS ID#: CT1500021

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**