

Washington – Judea Main System 2023 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	04-06-2023	None Detected
2	04-06-2023	None Detected
3	04-06-2023	None Detected
4	04-06-2023	None Detected
5	04-06-2023	None Detected
6	04-06-2023	None Detected
7	04-06-2023	None Detected
8	04-06-2023	None Detected
9	04-06-2023	None Detected
10	04-12-2023	None Detected
11	04-06-2023	1
12	04-06-2023	2
13	04-06-2023	4

PWS ID#: CT1500021

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.