



Wolcott - Clearview System
2019 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	04/26/19	None Detected
2	04/26/19	None Detected
3	04/26/19	None Detected
4	04/26/19	None Detected
5	04/26/19	1
6	04/26/19	1
7	04/26/19	1
8	04/26/19	2
9	04/26/19	2
10	04/26/19	2
11	04/26/19	3

PWS ID#: CT1668011

***For additional information, please refer to the *.pdf entitled: "CT Lead Compliance Testing Results – 90th Percentile Lead Concentration."**