



**Wolcott - Clearview System**  
**2020 Lead Compliance Testing Results**  
**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 1**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	04/03/20	None Detected
2	04/03/20	None Detected
3	04/03/20	None Detected
4	04/03/20	None Detected
5	04/03/20	None Detected
6	04/03/20	None Detected
7	04/03/20	None Detected
8	04/03/20	None Detected
9	04/03/20	None Detected
10	04/03/20	1
11	04/07/20	1
12	04/03/20	3

**PWS ID#: CT1668011**

**\*For additional information, please refer to the \*.pdf entitled: “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration.”**