



Wolcott - Woodrich Village System 2018 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	07/19/18	None Detected
2	07/19/18	None Detected
3	07/19/18	1
4	07/19/18	1
5	07/19/18	2
6	07/19/18	2
7	07/19/18	2
8	07/19/18	6

PWS ID#: CT1666011

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**