



Woodbury System
2020 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 1

Rank	Collection Date	Lead Results (ppb)
1	05/29/20	None Detected
2	05/29/20	None Detected
3	05/29/20	None Detected
4	05/29/20	None Detected
5	05/29/20	None Detected
6	05/29/20	None Detected
7	05/29/20	None Detected
8	05/29/20	None Detected
9	05/29/20	None Detected
10	05/29/20	None Detected
11	05/29/20	None Detected
12	05/29/20	None Detected
13	05/29/20	None Detected
14	05/29/20	None Detected
15	05/29/20	None Detected
16	05/29/20	None Detected
17	05/29/20	None Detected
18	05/29/20	None Detected
19	05/29/20	None Detected
20	05/29/20	None Detected
21	06/03/20	None Detected
22	05/29/20	1
23	05/29/20	1
24	05/29/20	1
25	05/29/20	3
26	05/29/20	12

PWS ID#: CT1680011

***For additional information, please refer to the *.pdf entitled: "CT Lead Compliance Testing Results – 90th Percentile Lead Concentration."**