

## Danbury – Indian Spring System 2021 Lead Compliance Testing Results

System is in Compliance

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 2**

Rank	Collection Date	Lead Results (ppb)
1	09-29-2021	None Detected
2	09-29-2021	None Detected
3	09-29-2021	None Detected
4	09-29-2021	None Detected
5	09-29-2021	None Detected
6	09-29-2021	None Detected
7	09-29-2021	None Detected
8	09-29-2021	None Detected
9	09-29-2021	1
10	09-29-2021	1
11	09-29-2021	2
12	09-29-2021	2
13	09-29-2021	2
14	09-29-2021	4

**PWS ID#: CT0340191**

\*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.