



East Hampton System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	06-17-2021	None Detected
2	06-17-2021	None Detected
3	06-17-2021	None Detected
4	06-17-2021	None Detected
5	06-17-2021	None Detected
6	06-17-2021	None Detected

PWS ID#: CT0420011

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.