



Goshen – Tyler Lake Heights System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	11-12-2021	None Detected
2	11-12-2021	None Detected
3	11-12-2021	None Detected
4	11-12-2021	None Detected
5	11-12-2021	None Detected
6	11-12-2021	None Detected
7	11-12-2021	None Detected
8	11-15-2021	None Detected
9	12-03-2021	None Detected
10	12-03-2021	None Detected
11	12-03-2021	None Detected
12	11-12-2021	6

PWS ID#: CT0550011

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.