



## Mansfield – Valley View System 2021 Lead Compliance Testing Results

### System is in Compliance

90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 8

Rank	Collection Date	Lead Results (ppb)
1	11-12-2021	None Detected
2	11-16-2021	None Detected
3	11-24-2021	None Detected
4	11-24-2021	None Detected
5	11-24-2021	None Detected
6	11-12-2021	2
7	11-24-2021	2
8	11-12-2021	3
9	11-12-2021	3
10	11-12-2021	6
11	11-12-2021	8
12	11-12-2021	46

PWS ID#: CT0780211

\*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.