



Marlborough – Marlborough System 2022 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 9

Rank	Collection Date	Lead Results (ppb)
1	06-03-2022	None Detected
2	06-03-2022	None Detected
3	06-03-2022	None Detected
4	06-03-2022	None Detected
5	06-07-2022	None Detected
6	06-07-2022	None Detected
7	06-07-2022	None Detected
8	06-07-2022	None Detected
9	06-07-2022	None Detected
10	06-07-2022	None Detected
11	06-07-2022	None Detected
12	06-07-2022	None Detected
13	06-03-2022	1
14	06-03-2022	1
15	06-07-2022	1
16	06-07-2022	1
17	06-07-2022	3
18	06-07-2022	4
19	06-07-2022	4
20	06-07-2022	4



21	06-07-2022	5
22	06-07-2022	8
23	06-07-2022	9
24	06-07-2022	9
25	06-03-2022	10
26	06-07-2022	14
27	06-07-2022	50

PWS ID#: CT0798013

***ppb = parts per billion**

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.