



## New Fairfield – Dunham Pond System 2021 Lead Compliance Testing Results

### System is in Compliance

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 10**

Rank	Collection Date	Lead Results (ppb)
1	09-09-2021	None Detected
2	09-09-2021	None Detected
3	09-09-2021	None Detected
4	09-09-2021	None Detected
5	09-09-2021	None Detected
6	09-09-2021	None Detected
7	09-09-2021	None Detected
8	09-09-2021	1
9	09-09-2021	1
10	09-09-2021	2
11	09-09-2021	2
12	09-09-2021	2
13	09-09-2021	2
14	09-09-2021	3
15	09-09-2021	3
16	09-09-2021	3
17	09-09-2021	4
18	09-09-2021	5
19	09-09-2021	10
20	09-09-2021	10
21	09-09-2021	10
22	09-09-2021	27

**PWS ID#: CT0915221**

\*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.