



New Fairfield – Dunham Pond System 2022 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 5

Rank	Collection Date	Lead Results (ppb)
1	04-21-2022	None Detected
2	04-21-2022	None Detected
3	04-21-2022	None Detected
4	04-21-2022	None Detected
5	04-21-2022	None Detected
6	04-21-2022	1
7	04-21-2022	2
8	04-21-2022	2
9	04-21-2022	2
10	04-21-2022	2
11	04-21-2022	2
12	04-21-2022	3
13	04-21-2022	3
14	04-21-2022	4
15	04-21-2022	4
16	04-21-2022	4
17	04-21-2022	7
18	04-21-2022	11

PWS ID#: CT0915221

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.