



New Fairfield – Oakwood Acres System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 4

Rank	Collection Date	Lead Results (ppb)
1	09-10-2021	None Detected
2	09-10-2021	None Detected
3	09-10-2021	None Detected
4	09-10-2021	None Detected
5	09-10-2021	None Detected
6	09-10-2021	None Detected
7	09-10-2021	1
8	09-10-2021	2
9	09-10-2021	2
10	09-17-2021	3
11	09-13-2021	4
12	09-13-2021	4
13	09-17-2021	4
14	09-14-2021	7

PWS ID#: CT0910031

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.