



New Fairfield – Oakwood Acres System 2022 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	03-31-2022	None Detected
2	03-31-2022	None Detected
3	03-31-2022	None Detected
4	03-31-2022	None Detected
5	03-31-2022	1
6	03-31-2022	1
7	03-31-2022	2
8	03-31-2022	2
9	03-31-2022	2
10	03-31-2022	2
11	03-31-2022	3
12	03-31-2022	3
13	03-31-2022	3
14	03-31-2022	3

PWS ID#: CT0910031

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.