



New Fairfield – Possum Ridge System 2022 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	03-31-2022	None Detected
2	03-31-2022	None Detected
3	03-31-2022	None Detected
4	03-31-2022	None Detected
5	03-31-2022	None Detected
6	04-05-2022	None Detected
7	04-12-2022	None Detected
8	03-31-2022	1
9	03-31-2022	2
10	03-31-2022	2

PWS ID#: CT0910041

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.