



New Milford – Forest Hill System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	06-18-2021	None Detected
2	06-18-2021	None Detected
3	06-18-2021	None Detected
4	06-18-2021	None Detected
5	06-18-2021	None Detected
6	06-18-2021	None Detected

PWS ID#: CT0960141

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.