



North Canaan System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	07-07-2021	None Detected
2	07-07-2021	None Detected
3	07-07-2021	None Detected
4	07-07-2021	None Detected
5	07-07-2021	None Detected
6	07-07-2021	None Detected
7	07-07-2021	None Detected
8	07-07-2021	None Detected
9	07-21-2021	None Detected
10	07-07-2021	1
11	07-07-2021	2
12	07-07-2021	4
13	07-07-2021	49

PWS ID#: CT100011

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.