



Hawkstone System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 1

Rank	Collection Date	Lead Results (ppb)
1	07-09-2021	None Detected
2	07-09-2021	None Detected
3	07-09-2021	None Detected
4	07-09-2021	None Detected
5	07-09-2021	None Detected
6	07-09-2021	None Detected
7	07-09-2021	None Detected
8	07-09-2021	1
9	07-09-2021	4

PWS ID#: CT1080011

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.