



Ridgefield – Craigmoor System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 8

Rank	Collection Date	Lead Results (ppb)
1	07-14-2021	None Detected
2	07-14-2021	None Detected
3	07-14-2021	1
4	07-14-2021	1
5	07-14-2021	2
6	07-14-2021	2
7	07-14-2021	2
8	07-14-2021	2
9	07-19-2021	2
10	07-14-2021	3
11	07-14-2021	3
12	07-14-2021	4
13	07-14-2021	6
14	07-14-2021	7
15	07-14-2021	10
16	07-14-2021	11

PWS ID#: CT1180071

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.