



## Ridgefield – Craigmoor System 2022 Lead Compliance Testing Results

System is in Compliance

90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 11

Rank	Collection Date	Lead Results (ppb)
1	06-17-2022	1
2	06-17-2022	2
3	06-17-2022	2
4	06-17-2022	2
5	06-17-2022	2
6	06-17-2022	5
7	06-17-2022	6
8	06-17-2022	6
9	06-17-2022	7
10	06-17-2022	11
11	06-17-2022	15

PWS ID#: CT1180071

\*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.