



## Ridgefield – Ridgefield Knolls System 2021 Lead Compliance Testing Results

### System is in Compliance

90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 4

Rank	Collection Date	Lead Results (ppb)
1	07-29-2021	None Detected
2	07-29-2021	None Detected
3	07-29-2021	None Detected
4	07-29-2021	None Detected
5	07-29-2021	None Detected
6	07-29-2021	None Detected
7	07-29-2021	None Detected
8	07-29-2021	None Detected
9	07-29-2021	None Detected
10	07-29-2021	2
11	07-29-2021	2
12	07-29-2021	3
13	07-29-2021	4
14	07-29-2021	16

**PWS ID#: CT1180021**

\*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.