



## Sherman – Timber Trails System 2021 Lead Compliance Testing Results

### System is in Compliance

90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 4

Rank	Collection Date	Lead Results (ppb)
1	11-12-2021	None Detected
2	11-12-2021	None Detected
3	11-12-2021	None Detected
4	11-12-2021	None Detected
5	11-12-2021	None Detected
6	11-12-2021	None Detected
7	11-12-2021	None Detected
8	11-12-2021	None Detected
9	11-12-2021	None Detected
10	11-17-2021	None Detected
11	12-13-2021	None Detected
12	12-13-2021	None Detected
13	12-13-2021	None Detected
14	12-13-2021	None Detected
15	12-13-2021	None Detected
16	12-13-2021	None Detected
17	11-12-2021	2
18	12-13-2021	4
19	11-12-2021	36
20	11-12-2021	70

PWS ID#: CT1270021

\*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.