



Stonington - Mystic System
2020 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 3

Rank	Collection Date	Lead Results (ppb)
1	04/14/21	None Detected
2	04/14/21	None Detected
3	04/14/21	None Detected
4	04/14/21	None Detected
5	04/14/21	None Detected
6	04/14/21	None Detected
7	04/14/21	None Detected
8	04/14/21	None Detected
9	04/14/21	None Detected
10	04/14/21	None Detected
11	04/14/21	None Detected
12	04/14/21	None Detected
13	04/14/21	None Detected
14	04/14/21	None Detected
15	04/14/21	None Detected
16	04/14/21	None Detected
17	04/14/21	None Detected
18	04/14/21	None Detected
19	04/14/21	None Detected
20	04/14/21	None Detected
21	04/14/21	None Detected
22	04/14/21	None Detected
23	04/14/21	None Detected
24	04/14/21	None Detected
25	04/14/21	None Detected
26	04/14/21	None Detected
27	04/14/21	None Detected
28	04/14/21	None Detected
29	04/14/21	None Detected
30	04/14/21	None Detected
31	04/14/21	None Detected



32	04/14/21	None Detected
33	04/14/21	None Detected
34	04/14/21	None Detected
35	04/14/21	None Detected
36	04/14/21	None Detected
37	04/14/21	None Detected
38	04/14/21	None Detected
39	04/14/21	None Detected
40	04/14/21	None Detected
41	04/14/21	None Detected
42	04/14/21	None Detected
43	04/14/21	None Detected
44	04/14/21	None Detected
45	04/14/21	None Detected
46	04/14/21	None Detected
47	04/14/21	None Detected
48	04/14/21	None Detected
49	04/14/21	None Detected
50	04/14/21	None Detected
51	04/14/21	None Detected
52	04/14/21	None Detected
53	04/14/21	1
54	04/14/21	1
55	04/14/21	1
56	04/14/21	1
57	04/14/21	2
58	04/14/21	2
59	04/14/21	3
60	04/14/21	3
61	04/14/21	4
62	04/14/21	5
63	04/14/21	7
64	04/14/21	13
65	04/14/21	14
66	04/14/21	353

PWS ID#: CT1370011

***For additional information, please refer to the *.pdf entitled: "CT Lead Compliance Testing Results – 90th Percentile Lead Concentration."**