



Suffield – Suffield Wells System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 1

Rank	Collection Date	Lead Results (ppb)
1	11-05-2021	None Detected
2	11-05-2021	None Detected
3	11-05-2021	None Detected
4	11-05-2021	None Detected
5	11-05-2021	None Detected
6	11-05-2021	None Detected
7	11-05-2021	None Detected
8	11-05-2021	None Detected
9	11-05-2021	None Detected
10	11-05-2021	None Detected
11	11-05-2021	None Detected
12	11-05-2021	None Detected
13	11-05-2021	None Detected
14	11-05-2021	None Detected
15	11-05-2021	None Detected
16	11-05-2021	None Detected
17	11-05-2021	None Detected
18	11-05-2021	1
19	11-05-2021	1
20	11-05-2021	1
21	11-05-2021	2
22	11-05-2021	48

PWS ID#: CT1390021

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.