



Suffield – Suffield Wells System
2021 Lead Compliance Testing Results
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 1

Rank	Collection Date	Lead Results (ppb)
1	04/09/21	None Detected
2	04/09/21	None Detected
3	04/09/21	None Detected
4	04/09/21	None Detected
5	04/09/21	None Detected
6	04/09/21	None Detected
7	04/09/21	None Detected
8	04/09/21	None Detected
9	04/09/21	None Detected
10	04/09/21	None Detected
11	04/09/21	None Detected
12	04/09/21	None Detected
13	04/09/21	None Detected
14	04/09/21	None Detected
15	04/09/21	None Detected
16	04/09/21	None Detected
17	04/09/21	None Detected
18	04/09/21	None Detected
19	04/09/21	None Detected
20	04/09/21	1
21	04/09/21	1
22	04/09/21	3
23	04/09/21	4

PWS ID#: CT1390021

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**