



## Suffield – Suffield System 2022 Lead Compliance Testing Results

System is in Compliance

90<sup>th</sup> Percentile Lead Concentration (ppb)\* = None Detected

Rank	Collection Date	Lead Results (ppb)
1	05-26-2022	None Detected
2	05-26-2022	None Detected
3	05-26-2022	None Detected
4	05-26-2022	None Detected
5	05-26-2022	None Detected
6	05-26-2022	None Detected
7	05-26-2022	None Detected
8	05-26-2022	None Detected
9	05-26-2022	None Detected
10	05-26-2022	None Detected
11	05-26-2022	None Detected
12	05-26-2022	None Detected
13	05-26-2022	None Detected
14	05-26-2022	None Detected
15	05-26-2022	None Detected
16	05-26-2022	None Detected
17	05-26-2022	None Detected
18	05-26-2022	None Detected
19	05-26-2022	None Detected
20	05-31-2022	None Detected
21	05-31-2022	None Detected
22	05-26-2022	1
23	05-26-2022	9

PWS ID#: CT1390021

\*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.