



## Washington – Judea Depot System 2021 Lead Compliance Testing Results

System is in Compliance

90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 14

Rank	Collection Date	Lead Results (ppb)
1	08-05-2021	None Detected
2	08-05-2021	None Detected
3	08-05-2021	None Detected
4	08-05-2021	1
5	09-29-2021	3
6	09-28-2021	5
7	08-05-2021	35

PWS ID#: CT1500091

\*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile” on the CT Lead Compliance Reports webpage.