



Washington – Judea Main System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 2

Rank	Collection Date	Lead Results (ppb)
1	09-24-2021	None Detected
2	09-24-2021	None Detected
3	09-24-2021	None Detected
4	09-24-2021	None Detected
5	09-24-2021	None Detected
6	09-24-2021	1
7	09-24-2021	1
8	09-24-2021	1
9	09-24-2021	2
10	09-24-2021	2
11	09-24-2021	4

PWS ID#: CT1500021

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.