



**Washington - Judea Main System
2021 Lead Compliance Testing Results**
System is in Compliance

90th Percentile Lead Concentration (ppb)* = 1

Rank	Collection Date	Lead Results (ppb)
1	03/15/21	None Detected
2	03/15/21	None Detected
3	03/15/21	None Detected
4	03/15/21	None Detected
5	03/15/21	None Detected
6	03/15/21	None Detected
7	03/15/21	None Detected
8	03/15/21	None Detected
9	03/15/21	None Detected
10	03/15/21	1
11	03/15/21	1
12	03/15/21	2

PWS ID#: CT1500021

***For additional information, please refer to the *.pdf entitled: “CT Lead Compliance Testing Results – 90th Percentile Lead Concentration.”**