



Wolcott – Woodrich Village System 2021 Lead Compliance Testing Results

System is in Compliance

90th Percentile Lead Concentration (ppb)* = 4

Rank	Collection Date	Lead Results (ppb)
1	09-17-2021	1
2	09-17-2021	1
3	09-17-2021	1
4	09-17-2021	2
5	09-17-2021	2
6	09-17-2021	3
7	09-17-2021	5

PWS ID#: CT1666011

*ppb = parts per billion

For additional information on compliance determinations, please refer to the PDF entitled “CT Lead Compliance Testing Results – 90th Percentile” on the CT Lead Compliance Reports webpage.