



**Woodbury System**  
**2021 Lead Compliance Testing Results**  
**System is in Compliance**

**90<sup>th</sup> Percentile Lead Concentration (ppb)\* = 2**

<b>Rank</b>	<b>Collection Date</b>	<b>Lead Results (ppb)</b>
1	03/15/21	None Detected
2	03/15/21	None Detected
3	03/15/21	None Detected
4	03/15/21	None Detected
5	03/15/21	None Detected
6	03/15/21	None Detected
7	03/15/21	None Detected
8	03/15/21	None Detected
9	03/15/21	None Detected
10	03/15/21	None Detected
11	03/15/21	None Detected
12	03/15/21	None Detected
13	03/15/21	None Detected
14	03/15/21	None Detected
15	03/15/21	None Detected
16	03/15/21	None Detected
17	03/15/21	None Detected
18	03/15/21	None Detected
19	03/15/21	None Detected
20	03/15/21	None Detected
21	03/15/21	None Detected
22	03/29/21	None Detected
23	03/15/21	2
24	03/25/21	2
25	03/15/21	3
26	03/15/21	5

**PWS ID#: CT1680011**

**\*For additional information, please refer to the \*.pdf entitled: "CT Lead Compliance Testing Results – 90<sup>th</sup> Percentile Lead Concentration."**



**AQUARION**  
*Water Company*

*Stewards of the Environment™*