

Compliance Lead Testing Aquarion Water Company

Lead concentration in water is measured in terms of parts per billion (ppb). Water systems are generally required to test the lead concentrations in the water every three years. This is done by collecting water samples at customers' taps and testing the lead concentration in these samples. A water system is in compliance with the regulations if 90% of the samples have a lead concentration at or below 15 ppb. The table below shows the results from our two most recent rounds of lead sampling. The 90th percentile lead concentration indicates the concentration below which 90 percent of the samples fall. For example, if a system has a 90th percentile lead concentration of 1 ppb, it means the lead concentration was less than 1 ppb in 90 percent of the samples.

If you have any questions about the information in this table, or the quality of the water delivered to your home, please call our Water Quality Management Department at 1-800-832-2373.

Town(s) Served	System Name	Most Recent Testing			Previous Testing		
		Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No	Year	90th Percentile Lead Concentration (ppb)	In Compliance? Yes/No
1 Hampton, North Hampton, Rye	Hampton System	2021	None Detected	<input checked="" type="checkbox"/> Yes	2020	None Detected	<input checked="" type="checkbox"/> Yes