

**Abenaki**  
**An Aquarion Water Company**  
**PFAS Sampling Results**

**Town/City: Gilford**

**Water System Name: Gilford Village**

All results reported as parts per trillion (ppt)

Sample Location	PFAS Contaminant	Sample Date Jan. 2021	RAA	NHDES MCL	Compliant Yes/No
Gilford Village Wells POE	PFOA	ND	ND	12	Yes
	PFOS	ND	ND	15	Yes
	PFHxS	ND	ND	18	Yes
	PFNA	ND	ND	11	Yes

**Definitions:**

**MCL** - Maximum Contaminant Level. The highest level of a contaminant that is allowed in drinking water.

**ND** - Not Detected

**POE** - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.

**RAA** - Running Annual Average. The average of all sample analytical results taken during the previous twelve calendar months. The average is recalculated by considering each new data point and dropping from consideration data points that are more than one year old.