

**Aquarion Water Company
PFAS Sampling Results**

Town/City: Bethel

		All Results Reported as parts per trillion (ppt)						TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
Water System Name	Sample Location	Test Date	PFOA	PFOS	PFHpA	PFHxS	PFNA			
Berkshire Corporate Park	3 Berkshire Blvd., Distribution Point	Jul. 2019	4	ND	ND	ND	ND	4	70	ND
Chimney Heights	Chimney Heights Well, POE	May 2019	4	5	ND	ND	ND	9	70	ND
	Chimney Heights Well, POE	Jun. 2021	4	4	ND	3	ND	11	70	4
	Chimney Heights Well, POE	Aug. 2021	7	6	3	3	ND	19	70	4

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.