

**Aquarion Water Company
PFAS Sampling Results**

Town/City: Bridgeport Metro

(Easton, Fairfield, Monroe, Newtown, Norwalk-Saugatuck Shores, Redding, Shelton, Stratford, Trumbull, Weston, Westport and Wilton)

| Water System Name | Sample Location | Test Date | All Results Reported as parts per trillion (ppt) | | | | | TOTAL PFAS (5) | Current CT DPH Guideline | Other PFAS Tested PFBS |
|-------------------|---|-----------|--|------|-------|-------|------|----------------|--------------------------|------------------------|
| | | | PFOA | PFOS | PFHpA | PFHxS | PFNA | | | |
| Bridgeport Metro | Trap Falls Reservoir, POE | Jun. 2019 | 5 | ND | ND | ND | ND | 5 | 70 | ND |
| | Trap Falls Reservoir, POE | Jun. 2021 | 3 | ND | ND | ND | ND | 3 | 70 | 2 |
| | Hemlocks Reservoir, POE | Jun. 2019 | 2 | ND | ND | ND | ND | 2 | 70 | ND |
| | Hemlocks Reservoir, POE | Jun. 2021 | ND | ND | ND | ND | ND | ND | 70 | ND |
| | Easton Lake Reservoir, POE | Jun. 2019 | 3 | ND | ND | ND | ND | 3 | 70 | ND |
| | Easton Lake Reservoir, POE | Jun. 2021 | 2 | ND | ND | ND | ND | 2 | 70 | ND |
| | Canal Street Wells, POE | Jun. 2019 | 4 | 5 | ND | 4 | ND | 13 | 70 | ND |
| | Canal Street Wells, POE | Jun. 2021 | 4 | 5 | 3 | ND | ND | 12 | 70 | 3 |
| | Canal Street Wells, POE | Aug. 2021 | 5 | 5 | ND | 2 | ND | 12 | 70 | 2 |
| | Coleytown Wells, POE | Jun. 2019 | 4 | 4 | ND | ND | ND | 8 | 70 | ND |
| | Coleytown Wells, POE | Jun. 2021 | 7 | 4 | 3 | ND | ND | 14 | 70 | 2 |
| | Coleytown Wells, POE | Aug. 2021 | 8 | 5 | 3 | 2 | ND | 18 | 70 | ND |
| | Housatonic Wells, POE - NOT IN SERVICE | - | - | - | - | - | - | - | 70 | - |

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.