

**Aquarion Water Company**  
**PFAS Sampling Results**

**Town/City: Brookfield**

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
Brookfield Main	Brookfield Wells, POE	Jun. 2019	4	ND	ND	ND	ND	4	70	ND
	Brookfield Wells, POE	Sep. 2021	4	3	ND	ND	ND	7	70	6
	Brook Acres Wells, POE	Jun. 2019	3	ND	ND	ND	ND	3	70	ND
	Brook Acres Wells, POE	Sep. 2021	3	7	ND	3	ND	13	70	ND
	Towne Brooke Wells, POE	Jun. 2019	ND	ND	ND	ND	ND	ND	70	ND
	Towne Brooke Wells, POE	Sep. 2021	ND	ND	ND	ND	ND	ND	70	ND
Brookwood	Brookwood Wells, POE	Sep. 2019	4	ND	ND	ND	ND	4	70	ND
Butternut	Butternut Wells, POE	Jun. 2019	4	ND	ND	ND	ND	4	70	ND
	Butternut Wells, POE	Sep. 2019	3	3	ND	ND	ND	6	70	4
Hickory Hills	Hickory Hills Wells, POE	Sep. 2019	ND	ND	ND	ND	ND	ND	70	ND
	Hickory Hills Wells, POE	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND
Indian Fields	Indian Fields Wells, POE	Sep. 2019	5	ND	ND	ND	ND	5	70	ND
	Indian Fields Wells, POE	Jun. 2021	5	3	ND	ND	ND	8	70	ND
Western Brookfield	Western Brookfield Wells, POE	Sep. 2019	9	10	3	4	ND	26	70	ND
	Western Brookfield Wells, POE	Mar. 2020	6	8	ND	3	ND	17	70	3
	Western Brookfield Wells, POE	Aug. 2020	8	8	2	4	ND	22	70	3
	Western Brookfield Wells, POE	Oct. 2020	8	10	2	4	ND	24	70	4
	Western Brookfield Wells, POE	Aug. 2021	8	12	2	3	ND	25	70	3

**Definitions:**

**ND** - Not Detected

**POE** - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.