

**Aquarion Water Company
PFAS Sampling Results**

Town/City: Darien

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
Darien	Post Road Station, Distribution Point	Aug. 2019	5	ND	2	ND	ND	7	70	ND
	Springdale, Distribution Point	Aug. 2019	4	ND	2	ND	ND	6	70	ND
	Rewak Well, POE	Nov. 2020	13	10	4	4	ND	31	70	5

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.