

Aquarion Water Company
PFAS Sampling Results

Town/City: Lakeville / Salisbury

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
Lakeville	Pettee Street Wells, POE	May 2019	ND	ND	ND	ND	ND	ND	70	ND
	Pettee Street Wells, POE	Jul. 2021	ND	ND	ND	ND	ND	ND	70	ND
	Salisbury Wells, POE	May 2019	3	ND	ND	ND	ND	3	70	ND
	Salisbury Wells, POE	Jun. 2021	2	4	ND	ND	ND	6	70	ND
	Lakeville Reservoir, POE	May 2019	ND	ND	ND	ND	ND	ND	70	ND
	Lakeville Reservoir, POE	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.