

Aquarion Water Company
PFAS Sampling Results

Town/City: Marlborough

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
Birchwood Estates	Birchwood Wells, POE	Jul. 2019	ND	ND	ND	ND	ND	ND	70	ND
	Birchwood Wells, POE	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND
	Hillside Corp	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND
	Marlborough Municipal	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.