

Aquarion Water Company
PFAS Sampling Results

Town/City: New Fairfield

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
Ball Pond	Gillotti Wells, POE	Jun. 2019	6	5	ND	ND	ND	11	70	ND
	Gillotti Wells, POE	Aug. 2020	5	3	ND	ND	ND	8	70	2
	Gillotti Wells, POE	Jun. 2021	5	4	ND	ND	ND	9	70	3
	Renda Wells, POE	Jun. 2019	7	12	2	3	ND	24	70	ND
	Renda Wells, POE	Feb. 2020	6	6	ND	2	ND	14	70	4
	Renda Wells, POE	Aug. 2020	3	7	ND	ND	ND	10	70	3
	Renda Wells, POE	Oct. 2020	3	6	ND	ND	ND	9	70	4
	Renda Wells, POE	Feb. 2021	4	6	ND	ND	ND	10	70	3
	Renda Wells, POE	Jun. 2021	4	6	ND	3	ND	13	70	4
	Renda Wells, POE	Aug. 2021	4	8	ND	3	ND	15	70	5
	Biggs Wells, POE	Dec. 2019	8	19	ND	4	ND	31	70	3
	Biggs Wells, POE	Feb. 2020	7	18	ND	4	ND	29	70	2
	Biggs Wells, POE	Aug. 2020	4	9	ND	3	ND	16	70	4
	Biggs Wells, POE	Oct. 2020	5	14	ND	4	ND	23	70	2
	Biggs Wells, POE	Feb. 2021	5	13	ND	4	ND	22	70	2
	Biggs Wells, POE	Jun. 2021	6	13	ND	3	ND	22	70	2
Biggs Wells, POE	Aug. 2021	7	15	ND	3	ND	25	70	3	
Birches	Birches Wells, POE	Jul. 2019	2	ND	ND	ND	ND	2	70	ND
	Birches Wells, POE	Jun. 2021	ND	3	ND	ND	ND	3	70	ND
Dunham Pond	Dunham Pond Wells, POE	Jun. 2019	4	ND	ND	ND	ND	4	70	ND
	Dunham Pond Wells, POE	Jul. 2019	3	ND	ND	ND	ND	3	70	ND
	Dunham Pond Wells, POE	Jun. 2021	3	ND	ND	ND	ND	3	70	2
New Fairfield WPCA	New Fairfield WPCA, POE	Feb. 2021	ND	ND	ND	ND	ND	ND	70	ND
	New Fairfield WPCA, POE	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND
Fieldstone Ridge	Fieldstone Ridge Wells, POE	Jun. 2019	ND	ND	ND	ND	ND	ND	70	ND
	Fieldstone Ridge Wells, POE	Jul. 2019	ND	ND	ND	ND	ND	ND	70	ND
	Fieldstone Ridge Wells, POE	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND
Interlaken	Interlaken Well, POE	Apr. 2019	ND	ND	ND	ND	ND	ND	70	ND
	Interlaken Well, POE	Jun. 2021	ND	ND	ND	3	ND	3	70	ND
Oakwood Acres	Oakwood Acres Wells, POE	Jun. 2019	9	10	2	3	2	26	70	ND
	Oakwood Acres Wells, POE	Jul. 2019	6	6	ND	ND	ND	12	70	ND
	Oakwood Acres Wells, POE	Feb. 2020	7	7	ND	3	ND	17	70	ND
	Oakwood Acres Wells, POE	Aug. 2020	7	6	ND	2	ND	15	70	ND
	Oakwood Acres Wells, POE	Oct. 2020	6	8	ND	2	ND	16	70	3
	Oakwood Acres Wells, POE	Feb. 2021	6	8	ND	2	ND	16	70	ND
	Oakwood Acres Wells, POE	Jun. 2021	7	10	ND	3	ND	20	70	2
	Oakwood Acres Wells, POE	Aug. 2021	7	8	2	3	ND	20	70	2
Possum Ridge	Possum Ridge Wells 2&3, POE	Jul. 2019	2	ND	ND	ND	ND	2	70	ND
	Possum Ridge Wells 2&3, POE	Jun. 2021	ND	2	ND	ND	ND	2	70	ND

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.