

Aquarion Water Company
PFAS Sampling Results

Town/City: New Milford

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
Carmen Hill	Carmen Hill Wells, POE	May 2019	ND	ND	ND	ND	ND	ND	70	ND
	Carmen Hill Wells, POE	Jun. 2021	3	ND	3	ND	ND	6	70	4
Dean Heights	Dean Heights Wells, POE	May 2019	4	5	ND	ND	ND	9	70	ND
	Dean Heights Wells, POE	Jun. 2021	3	4	ND	ND	ND	7	70	2
Forest Hills Estates	Forest Hills Well #1A, POE	May 2019	3	ND	ND	3	ND	6	70	ND
	Forest Hills Well #1A, POE	Jun. 2021	3	ND	ND	4	ND	7	70	ND
	Forest Hills Well #2, POE	May 2019	3	ND	ND	ND	ND	3	70	ND
	Forest Hills Well #2, POE	Jun. 2021	3	ND	ND	3	ND	6	70	ND
Laurel Ridge/Laurel View	Laurel Ridge Wells, POE	Oct. 2019	ND	ND	ND	ND	ND	ND	70	ND
	Laurel Ridge Wells, POE	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND
Meadowbrook	Meadowbrook Wells, POE	May 2019	4	ND	ND	ND	ND	4	70	ND
	Meadowbrook Wells, POE	Jun. 2021	6	6	2	2	ND	16	70	3
	Meadowbrook Wells, POE	Aug. 2021	6	6	2	ND	ND	14	70	3
New Milford Main	Peagler Well #1, POE	May 2019	ND	ND	ND	ND	ND	ND	70	ND
	Peagler Well #1, POE	Jun. 2021	2	ND	ND	ND	ND	2	70	3
	Peagler Wells #2/3, POE	May 2019	2	ND	ND	ND	ND	2	70	ND
	Peagler Wells #2/3, POE	Jun. 2021	3	2	ND	ND	ND	5	70	ND
	Indian Field Wells #4/5/6, POE	May 2019	ND	ND	ND	ND	ND	ND	70	ND
	Indian Field Wells #4/5/6, POE	Jun. 2021	2	ND	ND	ND	ND	2	70	ND
Park Glen	Park Glen Wells, POE	May 2019	ND	ND	ND	ND	ND	ND	70	ND
	Park Glen Wells, POE	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND
Pleasant View	Pleasant View Wells, POE	May 2019	2	ND	ND	ND	ND	2	70	ND
	Pleasant View Wells, POE	Jun. 2021	2	3	ND	ND	ND	5	70	4
Twin Oaks	Twin Oaks Wells, POE	May 2019	ND	ND	ND	ND	ND	ND	70	ND
	Twin Oaks Wells, POE	Jun. 2021	ND	ND	ND	ND	ND	ND	70	ND

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.