

**Aquarion Water Company**  
**PFAS Sampling Results**

**Town/City: North Canaan**

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
North Canaan	North Canaan Wells, POE	May 2019	ND	ND	ND	ND	ND	70	ND	
	North Canaan Wells, POE	Jun. 2021	ND	ND	ND	ND	ND	70	ND	

**Definitions:**

**ND** - Not Detected

**POE** - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.