

Aquarion Water Company
PFAS Sampling Results

Town/City: Seymour / Oxford / Beacon Falls

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
Seymour	Oxford Wells 1+7, POE	May 2019	ND	ND	ND	ND	ND	70	ND	
	Oxford Wells 1+7, POE	Jun. 2021	2	3	2	4	ND	11	3	
	Oxford Well 2, POE	May 2019	ND	ND	ND	ND	ND	70	ND	
	Oxford Well 2, POE	Jun. 2021	ND	ND	ND	ND	ND	70	ND	
	Oxford Wells 5+6, POE	May 2019	ND	ND	ND	ND	ND	70	ND	
	Oxford Wells 5+6, POE	Jun. 2021	2	3	ND	3	ND	8	4	
	Maple Street, Distribution Point	Jun. 2019	ND	ND	ND	ND	ND	70	ND	
	Maple Street, Distribution Point	Jun. 2021	ND	ND	ND	ND	ND	70	ND	

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.