

Aquarion Water Company
PFAS Sampling Results

Town/City: Wolcott

Water System Name	Sample Location	Test Date	All Results Reported as parts per trillion (ppt)					TOTAL PFAS (5)	Current CT DPH Guideline	Other PFAS Tested PFBS
			PFOA	PFOS	PFHpA	PFHxS	PFNA			
Clearview Hills	Clearview, Distribution Point	Sep. 2019	4	ND	ND	ND	ND	4	70	ND
Woodrich Village	Woodrich Village Wells, POE	Sep. 2019	5	5	ND	ND	ND	10	70	ND
	Woodrich Village Wells, POE	Jun. 2021	4	5	ND	2	ND	11	70	3

Definitions:

ND - Not Detected

POE - point of entry. Sample collected after treatment as water enters the distribution system, before the first customer.