

**Aquarion Water Company
PFAS Sampling Results**

Ball Pond System Results

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	Effective 6/15/22	PFOS	Effective 6/15/22	PFHxS	Effective 6/15/22	PFNA	Effective 6/15/22
				CT DPH PFOA Action Level		CT DPH PFOS Action Level		CT DPH PFHxS Action Level		CT DPH PFNA Action Level
Ball Pond	Gillotti Wells, POE	Jun. 2019	6	16	5	10	ND	49	ND	12
	Gillotti Wells, POE	Aug. 2020	5		3		ND		ND	
	Gillotti Wells, POE	Jun. 2021	5		4		ND		ND	
	Gillotti Wells, POE	Apr. 2022	5		5		ND		ND	
	Renda Wells, POE	Jun. 2019	7		12		3		ND	
	Renda Wells, POE	Feb. 2020	6		6		2		ND	
	Renda Wells, POE	Aug. 2020	3		7		0		ND	
	Renda Wells, POE	Oct. 2020	3		6		0		ND	
	Renda Wells, POE	Feb. 2021	4		6		0		ND	
	Renda Wells, POE	Jun. 2021	4		6		3		ND	
	Renda Wells, POE	Aug. 2021	4		8		3		ND	
	Renda Wells, POE	Apr. 2022	6		8		0		ND	
	Biggs Wells, POE	Dec. 2019	8		19		4		ND	
	Biggs Wells, POE	Feb. 2020	7		18		4		ND	
	Biggs Wells, POE	Aug. 2020	4		9		3		ND	
	Biggs Wells, POE	Oct. 2020	5		14		4		ND	
	Biggs Wells, POE	Feb. 2021	5		13		4		ND	
	Biggs Wells, POE	Jun. 2021	6		13		3		ND	
	Biggs Wells, POE	Aug. 2021	7		15		3		ND	
	Biggs Wells, POE	Apr. 2022	7		15		3		ND	

Footnotes:

A yellow highlighted value denotes a historical concentration that is greater than the new Connecticut Department of Public Health Action Level established on June 15, 2022

Definitions:

ND - Not Detected

POE - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.