

**Aquarion Water Company  
PFAS Sampling Results**

**Brookfield Area of New Milford Regional System Results**

All Results Reported as parts per trillion (ppt)

Water System Name	Sample Location	Test Date	PFOA	Effective 6/15/22	PFOS	Effective 6/15/22	PFHxS	Effective 6/15/22	PFNA	Effective 6/15/22
				CT DPH PFOA Action Level		CT DPH PFOS Action Level		CT DPH PFHxS Action Level		CT DPH PFNA Action Level
New Milford Main	Peagler Well #1, POE	May 2019	ND	16	ND	10	ND	49	ND	12
	Peagler Well #1, POE	Jun. 2021	2		ND					
	Peagler Wells #2/3, POE	May 2019	2		ND					
	Peagler Wells #2/3, POE	Jun. 2021	3		2					
	Indian Field Wells #4/5/6, POE	May 2019	ND		ND					
	Indian Field Wells #4/5/6, POE	Jun. 2021	2		ND					
	Brookfield Wells, POE	Jun. 2019	4		ND					
	Brookfield Wells, POE	Sep. 2021	4		3					
	Brook Acres Wells, POE	Jun. 2019	3		ND					
	Brook Acres Wells, POE	Sep. 2021	3		7					
	Towne Brooke Wells, POE	Jun. 2019	ND		ND					
	Towne Brooke Wells, POE	Sep. 2021	ND		ND					
	Brookwood Wells, POE	Sep. 2019	4		ND					
	Western Brookfield Wells, POE	Sep. 2019	9		10					
	Western Brookfield Wells, POE	Mar. 2020	6		8					
	Western Brookfield Wells, POE	Aug. 2020	8		8					
	Western Brookfield Wells, POE	Oct. 2020	8		10					
	Western Brookfield Wells, POE	Aug. 2021	8		12					
Western Brookfield Wells, POE	Apr. 2022	8	10							

**Footnotes:**

A yellow highlighted value denotes a historical concentration that is greater than the new Connecticut Department of Public Health Action Level established on June 15, 2022

**Definitions:**

**ND** - Not Detected

**POE** - Point of Entry. Sample collected after treatment as water enters the distribution system, before the first customer.